



**Renfrew**  
Bridging Charm and Convenience

**Town of Renfrew**  
127 Raglan Street South  
Renfrew, Ontario  
K7V 1P8

## **Addendum No. 1**

---

Date: June 6, 2025

Project No. 2025-02-IPWE

Project: Ma-te-way Park Drive Watermain Replacement

To: All Bidders

---

### **TO ALL TENDERERS**

This Addendum shall form part of the Contract Documents and **shall be noted on Page 9** of the Tender Form. Ensure that all parties and subtrades submitting bids are aware of the items included in this Addendum.

### **TENDER AND BONDING INFORMATION**

No changes have been made.

### **CHANGES TO FORM OF TENDER**

No changes have been made.

### **CHANGES TO THE SPECIAL PROVISIONS – GENERAL**

No changes have been made.

### **CHANGES TO THE SPECIAL PROVISIONS – ITEMS**

Item No. 7 – Granular ‘A’ Base and Granular ‘B’ Subbase For Roadway of the Special Provisions item is modified as follows:

OPSS.MUNI 314 Construction Specification for Untreated Granular Subbase, Base, Surface, Shoulder and Stockpiling is amended as follows:

#### **314.05 MATERIALS**

**Subsection 314.05.03 (Granular ‘B’ Type I Modified)** is added as follows:



Granular 'B' Type I Modified will be permitted as a substitution for Granular 'B' Type II. The Granular 'B' Type I Modified material for subbase must meet the following gradation requirements.

<u>MTO Sieve Designation</u>	<u>Percent Passing by Mass</u>
150 mm	100
100 mm	100
37.5 mm	60 – 80
26.5 mm	50 – 70
4.75 mm	20 – 55
1.18 mm	10 – 40
300 µm	5 – 22
75 µm	0 – 10

Granular 'B' Type I Modified material supplied must be capable of being compacted sufficiently for use as road sub-base material using standard construction practices without being altered or requiring extraordinary measures.

Granular 'B' Type I Modified material to be supplied under this Contract must contain a minimum 50% crushed particles.

## **CHANGES TO THE CONTRACT DRAWINGS**

No changes have been made.

## **PRE-BID QUESTIONS**

1. **Question:** Can we substitute BI modified in lieu of BII as it has been used on many projects before?

**Answer:** Granular 'B' Type I Modified will be permitted as a substitution for Granular 'B' Type II. The requirements for Granular 'B' Type I Modified have been added to Item 7 - Granular 'A' Base and Granular 'B' Subbase For Roadway of the Special Provisions item.

2. **Question:** Do we have to place a number for supplemental or can we leave it blank?

**Answer:** In the event that the Contractors operations will allow the existing watermain to remain in service during the installation of the new watermain, then the installation of a temporary watermain will not be required, and the bidder can



**Renfrew**  
Bridging Charm and Convenience

**Town of Renfrew**  
**127 Raglan Street South**  
**Renfrew, Ontario**  
**K7V 1P8**

enter "0.00\$" in the form of tender for the Supplement Local Water Supply item. With this said, 12-hour watermain shutdowns to the residences will be permitted to make connections from the new watermain to the existing watermain.

**Please attach this addendum to your Tender document and be governed accordingly. Bidders must acknowledge receipt of all addenda.**

One copy of this Addendum is to be SIGNED and SUBMITTED with the Tender

\_\_\_\_\_  
TENDERER'S NAME (Company)

Date of Issue – June 6, 2025

Closing Date – June 12, 2025

\_\_\_\_\_  
SIGNATURE

Closing Time – 2:00 PM

\_\_\_\_\_  
NAME (Please Print)

Jp2g Consultants Inc.  
Engineers • Planners • Project Managers

\_\_\_\_\_  
DATE