



Renfrew
Bridging Charm and Convenience

Town of Renfrew
127 Raglan Street South
Renfrew, Ontario
K7V 1P8

Addendum No. 1

Date: August 26, 2025

Project No. 2025-11-IPWE

Project: Seventh Street Rehabilitation

To: All Bidders

Pre-Bid Questions

1. Question: Can you please confirm the existing depth of asphalt.

Answer: The existing site conditions are included in the Pavement Design Report (Section G). Existing asphalt thickness varies but is generally 50-55mm.

2. Question: Following asphalt removal, please specify how many days granular surfaces are permitted.

Answer: The roadway shall not be left on a granular surface for more than **5 consecutive working days** before the first lift of asphalt is placed, unless otherwise approved by the Contract Administrator. The Contractor shall maintain granular surfaces in a safe, dust-free condition at all times.

Please attach this addendum to your proposal document and be governed accordingly. Bidders must acknowledge receipt of all addenda.

One copy of this Addendum is to be SIGNED and SUBMITTED with the Proposal

Proponent's Name (Company)

Date of Issue – August 15, 2025

Signature

Closing Date – August 28, 2025

Name (Please Print)

Closing Time – 2:00 PM

Date