



Renfrew
Bridging Charm and Convenience

Town of Renfrew
127 Raglan Street South
Renfrew, Ontario
K7V 1P8

Addendum No. 1

Date: September 8, 2026

Project No. 2026-16-IPWE

Project: 2026 Storm and Sanitary Sewer Cleaning and CCTV Inspection

To: All Bidders

Pre-Bid Questions

1. **Question:** Is there a cost to the contractor for disposing of waste generated from cleaning storm sewers at the Town of Renfrew's Gravel Pit located at 480 Bruce Street?

Answer: There will be no cost for disposing waste generated from cleaning storm sewers at the Town of Renfrew's Gravel Pit located at 480 Bruce Street.

2. **Question:** Does the Town of Renfrew have a MECP approved septage receiving site to dispose of the waste generated from cleaning sanitary sewers? If so, is there a cost to the contractor for this service?

Answer: The Town of Renfrew does not have any sites able to receive waste generated from cleaning sanitary sewers.

3. **Question:** Is decanting the water phase from sanitary sewer cleaning to a downstream manhole permitted?

Answer: Yes, decanting the water phase from sanitary sewer cleaning to a downstream manhole is permitted.

4. **Question:** Are sanitary laterals required to be inspected?

Answer: No sanitary laterals are not required to be inspected.

5. **Question:** Will additional inspection of sewers be compensated to the Contractor if any section of sewer is determined by the Town to be insufficiently clean to permit an acceptable video?

Answer: As per the contract, CCTV inspection of pipelines will be as per OPSS 409.MUNI.

Please attach this addendum to your Tender document and be governed accordingly. Bidders must acknowledge receipt of all addenda.

One copy of this Addendum is to be SIGNED and SUBMITTED with the Proposal

Proponent's Name (Company)

Date of Issue – August 27, 2026

Signature

Closing Date – September 10, 2026

Closing Time – 2:00 PM

Name (Please Print)

Date